

**Rajasthan Medical Services Corporation Limited, Jaipur**

'D'-block, swasthya Bhawan, Tilak Marg, C-Scheme, Jaipur

Phone no. 0141-2223887, Fax no. 0141-2228065

E-mail: edepmrmse-rj@nic.in

CIN : U24232RJ2011SGC035067

Website: <http://rmsc.health.rajasthan.gov.in>

No. F-8( ) RMSC/EPM/M-1/NIB-659/2022-23/ 671

Dated: 20/12/22

All Principals Medical Colleges,  
All the Superintendents of Medical Colleges & Attached Hospitals.  
Director (PH/HIA/IEC/AIDS/RCH)

**Sub:- Approval/Purchase of Item, 'DG Set (5 KVA)', for the Rate Contract and supply, ending on 30.11.2024.**

Please find enclosed herewith approved firm and DG Set (5 KVA), for the rate contract and supply ending on 30.11.2024. The rate contract and its terms & conditions are also available on Rajasthan Medical Services Corporation Ltd., Website [www.rmsc.health.rajasthan.gov.in](http://www.rmsc.health.rajasthan.gov.in)

In reference to the above rate contract No. F-8( ) RMSC/EPM/M-1/2021-22/NIB-659/.....Dated..... the supplier has executed the agreement with RMSC, as enclosed herewith for your information & necessary action. This bears an approval of M.D., RMSCL, Jaipur.



Executive Director (EPM)

Rajasthan Medical Services Corporation Ltd., Jaipur

No. F-8( ) RMSC/EPM/M-1/NIB-659/2022-23/ 671

Dated: 20/12/22

Copy forwarded to the following for information & necessary action:

1. P.S. to Hon'ble Health Minister, Medical & Health Deptt. Govt. of Rajasthan.
2. P.S. to ACS, Medical Health & FW Deptt. Rajasthan, Jaipur.
3. PS to Pr. Secy/Secy, Medical Education Department, Rajasthan, Jaipur
4. P.S. to Mission Director NHM Jaipur.
5. PA to Managing Director, RMSCL
6. Director, (PH)/(Aids)/(FW)/(RCH)/(IEC)/(ESI).
7. Principal, Medical College, Ajmer, Bikaner, Jaipur, Jodhpur, Kota, Jhalawar & Udaipur.
8. Principal R.U.H.S. College of Dental Science Jaipur.
9. Principal, RUHS College of Medical Sciences, Jaipur.
10. Superintendent Japuriya Hospital Jaipur (Associated with RUHS College of Medical Sciences, Jaipur).
11. Superintendent, SMS Hospital, Zenana Hospital, MahilaChikitsalya, Mental Hospital, J.K. Lon Hospital, T.B & Chest Hospital, Jaipur.
12. Superintendent Associated Group of Hospital-Ajmer, M.G. Hospital, Jodhpur, Ummaid Hospital- Jodhpur, PBM Hospital-Bikaner, MBS Hospital-Kota & A.G. Hospital-Udaipur.
13. Director, Medical & Health Services (ESI), Mobile Surgical Unit, Raj. Jaipur.
14. Addl. Director, Medical & Health Services (PW)/(RH)/(Hospital Admn.)
15. Joint Director, Medical & Health Services, (Zone) Jaipur, Ajmer, Udaipur, Jodhpur, Bikaner, Kota & Bharatpur.
16. All P.M.O.'s.
17. All CM&HO's.
18. All Dy. CM&HO's.
19. AGM (IT), RMSC, Jaipur
20. All BME, RMSC
21. M/s Skyline Power Solutions, New Delhi.
22. Guard file.



Executive Director (EPM)

Rajasthan Medical Services Corporation Ltd., Jaipur

**Rajasthan Medical Services Corporation Limited, Jaipur**

Gandhi Block, SwasthyaBhawan, TilakMarg, C-Scheme, Jaipur - 302005

Ph. No. 0141-2223887, Fax : 0141-2228065

E-mail : edepmrmisc-rj@nic.in

CIN:U24232RJ2011SGC035067

Website: http://rmisc.health.rajasthan.gov.in

No. F-8( ) RMSC/EPM/M-1/NIB-659/2022-23/ 67/

Dated: 20/12/22

**Rate Contract and Price Details**

S.N.	Item	Detail
1.	Name of Equipment / Item	DG Set (5 KVA)
2.	Name & Address of Firm	M/s Skyline Power Solutions, 13-14, Raja Garden, New Delhi-110015 Email: marketing@generator.co.in
3.	Bidder Status	Manufacturer
4.	Performance Security	Rs. 982645.00 Through NEFT HDFCR52022121467476577
5.	Brand/ Make	SwadeshiWhis Power
	Model	CDC100051D23
6.	Engine Make	Cooper
	Engine Model	1E1D1A6.95UA
7.	Packing Unit	Each
8.	R/C No. & Validity	R.C. No. 779 (Valid Up to 30.11.2024)
9.	Indicative Quantity	200
10.	<b>Rates for supply to RMSC from Suppliers</b>	
	(i) New Basic Rate (in Rs. )	166550.00
	(ii) IGST @ 18% (in Rs. )	29979.00
	(iii) CGST (in Rs. )	0.00
	(iv) SGST (in Rs. )	0.00
	(v) Approved Rate From Supplier To RMSC	196529.00
	{(i)+(ii)+(iii)+(iv)} (in Rs. )	
11.	<b>Rate For Supply to Consignee From RMSC</b>	
	(i) Basic Rate (in Rs.)	166550.00
	(ii) RMSC Surcharge@5% On (i) (in Rs.)	8327.50
	(iii) CGST@ 9% { On (i)+(ii)} (in Rs.)	15738.98
	(iv) SGST@ 9% { On (i)+(ii)} (in Rs.)	15738.98
	(v) Approved Rate for Consignee from RMSC	206355.46
	{(i)+(ii)+(iii)+(iv)} (in Rs.)	
12.	<b>Technical Specification of 5 KVA Diesel Generator Set:-</b>	
	1) Supply, Installation, Testing & Commissioning of Stationary/ MOVABLE ON WHEEL Silent DG Set complete with 1500/3000 RPM Diesel Engine of suitable BHP for 5KVA & AC Brushless Single Phase Alternator mounted on a common base Frame & coupled through coupling. Alternator shall be self regulated with standard Alternator Protection (Over voltage, over speed & under voltage, under speed warning & shutdown). Engine shall have residential silencer, exhaust piping, electronic/ Mechanical governor, Manual & electric Start, Batteries, Engine instruments panel, AVM and with Weatherproof, powder coated Acoustic enclosure for DG set for sound attenuation fabricated from 1.2 to 1.6mm CRCA sheet steel (structure) with side wall fabricated from 1.2 to 1.6 mm CRCA sheet & filled with Suitable thick glass wool (96Kg/m3)/ Foam. as per IS 8183, Suitable Thick doors and fabricated from 1.2mm - 1.6mm CRCA sheet packed with acoustic material, All doors/ opening are sealed with neoprene/EPDM	

*Signature*

*Signature*




- gaskets. The enclosure has built in fuel tank, residential silencer with protection and tripping of DG set.
- 2) Against temperature of more than 45 degree centigrade. All controls for operation of DG set are visible and accessible from outside the enclosure with automatic main failure(AMF) panel fabricated from CRCA sheet 1.2mm sheet CRCA sheet steel 1.2mm thick powder coated finish engine start stop command control relays, selector switches, multifunctional meter for ammeter & voltmeter, Control & power contractor, timers, electronic hotter, audio & visual alarm indication for faults, panel complete in all respect suitable for 5KVA, DG set also having microprocessor base genset monitoring and control systems including DP MCB of 30-40amp, 10ka capacity, 1 No., Frequency meter include power factor meter, frequency meter, indicating lamps, Enclosure should be suitable for 5KVA DG Set & Alternator, Noise level shall be less than 75dba at a distance of 1 meter dully certified by authorized agency completed in all respects according to capacity of 5 KVA.
  - 3) Naturally Air Cooled & Natural Aspirated/ Turbo Charged.
  - 4) 5 KVA at 0.8 to 1PF, Output Voltage 230V $\pm$ 2.5% 50Hz 1- $\phi$ .
  - 5) Relay Based: 5kVA.
  - 6) a) Providing PVC insulated flexible cooper conductor cable un-armoured 3x 10sqmm of ISI approved of make( upto 25meter).  
b) Providing 6sqmm single core flexible copper conductor of ISI approved of standard make in PVC pipe upto 25 meter including crimping lux both side of the wire for connecting to existing earth of building.
  - 7) suitable for maximum load of 4kw.
  - 8) Inbuilt Static Battery Charger Volts / Current (DC) 12V / 10 Amps
  - 9) Inbuilt Battery Voltage (DC) & Capacity (AH), 12 Voltage (DC)/ 35AH, Make- Amron or Exide including separate 24 month free Service/ Replacement Warranty.
  - 10) Fuel Consumption: Test certificate of quoted model from OEM at different load conditions must be provided at the time of technical bid. Fuel Tank Capacity: Minimum 15 L
  - 11) Voltage regulation : 230 $\pm$  2.5%
  - 12) All required wiring for panel/DG set should be in cooper flexible PVC insulated wire of standard makes.
  - 13) Installation/ Testing/ Connecting on load work done by firms as required at site.
  - 14) Bidder should Quote rates including installation work in all respect
  - 15) The firm should submit valid type of approved certificate with authorization from CPC/PCB following are the mandatory required certification :-  
A. Type of approval/COP data for emission compliance of diesel generator from ARAI/ICAT/VRDE.  
B. Type of approval/COP data for noise compliance of diesel generator from FCRI/ARAI/NAI/ICAT.
  - 16) Diesel Engine must have IS10001:1981 with updating till date.
  - 17) Complete work shall be carried out by the bidder.
  - 18) Warranty shall be given by OEM of the product and allied installation work for the period of 3years from the date of installation.
  - 19) Comprehensive Maintenance Service: CMC will be given @ 5% of net rate excluding GST (as applicable) and yearly escalation of 5% on last year's CMC price. The CMC may be awarded for five years (on yearly basis) after warranty period of three years.
  - 20) During warranty and onsite maintenance period consumables like all kind of filters, Engine oil, coolant, fan belt, washers and hose pipes will be provided by the department as and when required and two services/year will be will be provided by the manufacturer free of cost.
  - 21) Demonstration of the quoted item is must for final approval by the nominated technical committee at Jaipur. Fuel required for testing purpose is to bear by bidder.
  - 22) Other terms and condition to be covered during warranty period by the supplier:-
    1. Response time- < 24 Hours after logged the complain in complaint portal.
    2. Service hours- As per health facility schedule.
    - 3 Preventive Maintenance Schedule (PM)-As per OEM (Mention PM Schedule)

*Signature*

- |  |
|--|
| <p>4 Calibration Schedule – As per OEM (Mention PM Schedule)<br/>                     5 Technical &amp; Application Support, Demonstrations &amp; Trainings - As &amp; when required<br/>                     6 Toll Free No-<br/>                     7 Life of the equipment- As per OEM<br/>                     23) Authorization from OEM of Diesel Engine of DG Set shall be submitted along with technical bid.</p> |
|--|

- The agreement signed between RMSCL and the firm forms integral part of the rate contract.

  
 Executive Director (EPM)  
 RMSC, Jaipur  
 Dated: 20/12/22

No. F-8() RMSC/EPM/M-1/NIB-659/2022-23/ 67/

Copy forwarded to the following for information & necessary action:

1. P.S. to Hon'ble Health Minister, Medical & Health Deptt. Govt. of Rajasthan.
2. P.S. to ACS, Medical Health & FW Deptt. Rajasthan, Jaipur.
3. PS to Pr. Secy/Secy, Medical Education Department, Rajasthan, Jaipur
4. P.S. to Mission Director NHM Jaipur.
5. PA to Managing Director, RMSCL
6. Director, (PH)/(Aids)/(FW)/(RCH)/(IEC)/(ESI).
7. Principal, Medical College, Ajmer, Bikaner, Jaipur, Jodhpur, Kota, Jhalawar & Udaipur.
8. Principal R.U.H.S. College of Dental Science Jaipur.
9. Principal, RUHS College of Medical Sciences, Jaipur.
10. Superintendent Japuriya Hospital Jaipur (Associated with RUHS College of Medical Sciences, Jaipur).
11. Superintendent, SMS Hospital, Zenana Hospital, MahilaChikitsalya, Mental Hospital, J.K. Lon Hospital, T.B & Chest Hospital, Jaipur.
12. Superintendent Associated Group of Hospital-Ajmer, M.G. Hospital, Jodhpur, Ummaid Hospital- Jodhpur, PBM Hospital-Bikaner, MBS Hospital-Kota & A.G. Hospital-Udaipur.
13. Director, Medical & Health Services (ESI), Mobile Surgical Unit, Raj. Jaipur.
14. Addl. Director, Medical & Health Services (PW)/(RH)/(Hospital Admn.)
15. Joint Director, Medical & Health Services, (Zone) Jaipur, Ajmer, Udaipur, Jodhpur, Bikaner, Kota & Bharatpur.
16. All P.M.O.'s.
17. All CM&HO's.
18. All Dy. CM&HO's.
19. AGM (IT), RMSC, Jaipur
20. All BME, RMSC
21. M/s Skyline Power Solutions, New Delhi.
22. Guard file.

  
 Executive Director (EPM)  
 RMSC, Jaipur

*Tejas*