

## Rajasthan Medical Services Corporation Limited, Jaipur

'D'-block, swasthya Bhawan, Tilak Marg, C-Scheme, Jaipur

Phone no. 0141-2223887, Fax no. 0141-2228065

E-mail: edepmrm-sc-rj@nic.in

CIN : U24232RJ2011SGC035067

Website: http://rmsc.health.rajasthan.gov.in

No. F-8() RMSC/EPM/M-6/NIB-802/2023-24/ 55

Dated 26/4/2024

All Principals Medical Colleges,  
All the Superintendents of Medical Colleges & Attached Hospitals.  
Director (PH/HA/IEC/AIDS/RCH)

Sub:- Approval/Purchase of Item, "2 KVA UPS", for the Rate Contract and supply, ending on 31.01.2026.

Please find enclosed herewith approved firm and "2 KVA UPS", for the rate contract and supply ending on 31.01.2026. The rate contract and its terms & conditions are also available on Rajasthan Medical Services Corporation Ltd., Website www. rmsc.health.rajasthan.gov.in

In reference to the above rate contract no. F-8() RMSC/EPM/M-6/NIB-802/2023-24/... 55... dated 26/4/24 the supplier has executed the agreement with RMSC, as enclosed herewith for your information & necessary action. This bears an approval of M.D., RMSCL, and Jaipur.

Executive Director (EPM)  
Rajasthan Medical Services Corporation Ltd, Jaipur

No. F-8()RMSC/EPM/M-6/NIB-802/2023-24/

Dated

Copy forwarded to the following for information &amp; necessary action:

1. P.S. to Hon'ble Health Minister, Medical & Health Deptt. Govt. of Rajasthan.
2. P.S. to ACS/ PHS/ Secy., Medical Health & FW Deptt. Rajasthan, Jaipur.
3. PS to ACS/ PHS/ Secy., Medical Education Department, Rajasthan, Jaipur
4. P.S. to Mission Director, NHM Jaipur.
5. PA to Managing Director, RMSCL
6. Director, (PH)/(Aids)/(FW)/(RCH)/(IEC)/(ESI).
7. Principal, Medical College, Ajmer, Bikaner, Jaipur, Jodhpur, Kota, Jhalawar & Udaipur.
8. Principal R.U.H.S. College of Dental Science Jaipur.
9. Principal, RUHS College of Medical Sciences, Jaipur.
10. Superintendent Jaipuria Hospital Jaipur (Associated with RUHS College of Medical Sciences, Jaipur).
11. Superintendent, SMS Hospital, Zenana Hospital, Mahila Chikitsalya, Mental Hospital, J.K. Lon Hospital, T.B & Chest Hospital, Jaipur.
12. Superintendent Associated Group of Hospital-Ajmer, M.G. Hospital, Jodhpur, Ummaid Hospital- Jodhpur, PBM Hospital-Bikaner, MBS Hospital-Kota & A.G. Hospital-Udaipur.
13. Director, Medical & Health Services (ESI), Mobile Surgical Unit, Raj. Jaipur.
14. Addl. Director, Medical & Health Services (PW)/(RH)/(Hospital Admin.)
15. Joint Director, Medical & Health Services, (Zone) Jaipur, Ajmer, Udaipur, Jodhpur, Bikaner, Kota & Bharatpur.
16. All CM&HO's., All P.M.O.'s. and All Dy. CM&HO's, Rajasthan.
17. Joint Director (IT), for uploading in e-upkaran software and RMSCL website both.
18. All BME, RMSC
19. M/s RS Power System Pvt. Ltd., H1-85 RIICO Industrial Area, Mansarovar, Jaipur E-Mail:- rspower@rspowerindia.com. Validity unknown Signature valid
20. Guard file.

RajKaj Ref  
5663618

Digitally signed by D. Ankash Alha  
Designation: Executive Director  
Date: 2024.04.26 08:45 IST  
Reason: Approval  
Rajasthan Medical Services Corporation Ltd, Jaipur

# Rajasthan Medical Services Corporation Limited, Jaipur

Gandhi Block, SwasthyaBhawan, TilakMarg, C-Scheme, Jaipur - 302005

Ph. No. 0141-2223887, Fax : 0141-2228065

CIN:U24232RJ2011SGC035067

E-mail : edepmrmisc-rj@nic.in

Website: http://rmisc.health.rajasthan.gov.in

No. F-8(RMISC/EPM/M-6/NIB-802/2023-24/ 55

Dated 26/04/2024

## Rate Contract and Price Details

S.N.	Item	Detail
1.	Name of Equipment / Item	"2 KVA UPS"
2.	Name & Address of Firm	M/s RS Power System Pvt. Ltd., H1-85 RIICO Industrial Area, Mansarovar, Jaipur E-Mail: -rspower@rspowerindia.com
3.	Bidder Status	Manufacturer
4.	Performance Security	DD No 388832 Date 07.02.2024 for Rs 58,000.00 of Punjab National Bank, Sitapura Industrial Area, Jaipur (Raj)-3020222 Valid upto 31.07.2027
5.	Brand/Model	RS Power/ 2000 OL
	HSN Code	NA
7.	Packing Unit	Each
8.	R/C No. & Validity	R.C. No 844 (Valid Up to 31.01.2026)
9.	Indicative Quantity	100
10.	<b>Rates for supply to RMSC from Suppliers</b>	
	(i) Basic Rate (in Rs.)	49152.54
	(ii) IGST (in Rs.)	0.00
	(iii) CGST @ 9% (in Rs.)	4423.72
	(iv) SGST @ 9% (in Rs.)	4423.72
	(v) Approved Rate From Supplier To RMSC {(i)+(ii)+(iii)+(iv)} (in Rs.)	57999.99
16.	<b>Rate For Supply to Consignee From RMSC</b>	
	(i) Basic Rate (in Rs.)	49152.54
	(ii) RMSC Surcharge@5% On (i) (in Rs.)	2457.62
	(iii) CGST@ 9% { On (i)+(ii)} (in Rs.)	4644.91
	(iv) SGST@ 9% { On (i)+(ii)} (in Rs.)	4644.91
	(v) Approved Rate for Consignee from RMSC {(i)+(ii)+(iii)+(iv)} (in Rs.)	60899.98
22.	<b>Name of approved item(s) with full specification</b>	
Technical Specification for 2 KVA UPS		
1	Rating	2KVA On-Line UPS suitable for single phase AC input & single phase AC output, floor mounted type.
2	Back-up time	60 Minutes
3	Battery VAH	3200 VAH
4	General	(i) UPSs are free from workmanship defects, sharp edges, nicks, scratches, burs etc. All fasteners fixed properly. The equipment shall be complete with all parts and all parts shall be functional. (ii) UPS enclosure's degree of protection shall be as per IS 13947 (part 1)/ 1993 (reaffirmed 2004) (iii) Provision of manual By-pass facility for maintenance of UPS (iv) UPS shall supply output power and charging current at the same time. (v) UPS should have wheel mounted and all batteries should be kept in good quality iron case/cage.
5	Switching Device	MOSFET/IGBT
6	Switching Frequency	> 10 KHz
7	Input Voltage	160 V - 260V, 50 ± 3% Hz
8	Input Power factor	> 0.95 (lagging)
9	Output	230 V/ 220 V ± 1%, 50 ± 0.5 Hz

RajCap Ref: 5663618



Validity unknown Signature valid  
Digitally signed by D. Akash Atha  
Designation: Executive Director  
Date: 2024.04.26 10:08:45 IST  
Reason: Approved

10	KW rating of the UPS	0.7 time the KVA rating (Standard), 0.8/0.9 (optional)	
11	Voltage Regulation	Within $\pm 1\%$ (from no load to full load) for both single / three phase	
12	Facility for operation in synchronous mode	Provided i.e. Output frequency shall be same as that of mains frequency	
13	Total Harmonics distortion at output	2% maximum	When total input harmonics are $\leq 10\%$
14	Efficiency	At rated output KVA rating, rated power factor, rated voltage and frequency (overall efficiency): 90%	
15	Overload	UPS shall withstand 20 % overload for 10 minutes and 50 % overload for one minute	
16	Protections	<ul style="list-style-type: none"> <li>• Over voltage</li> <li>• Short Circuits</li> <li>• Overload at output terminal</li> <li>• Under voltage at battery terminal</li> <li>• Over shoot and under shoot : &lt; 4% of rated voltage for duration of 40 m sec. (maximum)</li> </ul>	
17	Indicators	<ul style="list-style-type: none"> <li>• Mains presence</li> <li>• Battery Charging &amp; discharging</li> <li>• Output overload</li> <li>• Low battery voltage</li> </ul>	
18	Meters	Provision of Digital Meter for monitoring the following parameters: <ul style="list-style-type: none"> <li>• Input AC voltage</li> <li>• Output AC voltage, current and frequency</li> <li>• Battery voltage &amp; current</li> </ul>	
19	Battery Bank	<ul style="list-style-type: none"> <li>• Battery Stand: Provided</li> <li>• Battery Make: Wiz-Exide/ Ammaraja /Relicell/Amron</li> </ul>	
20	CERTIFICATIONS AND TEST REPORT-All related test certificate /report shall be attached with technical bid.		
21	ISO	ISO 9001:2015, ISO 14001:2015	
22	Health & Safety	OHSAS 45001/ RoHS Compliant	
23	Standards	IEC EN 62040-1, IEC EN 62040-2, IEC EN 62040-3, IEC EN 62040-4, IEC EN 60146	
24	Marking	CE/ROHS	
25	Test Report	The bidder shall submit test report of similar or higher rating issued from Central Govt. Laboratory CPRI / ETDC (STQC)/ ERTL.	

- The agreement signed between RMSCL and the firm forms integral part of the rate contract.

Executive Director (EPM)  
RMSC, Jaipur

Dated 26/04/2024

No. F-8(RMSC/EPM/M-6/NIB-802/2023-24/ 55


Copy forwarded to the following for information & necessary action:

1. P.S. to Hon'ble Health Minister, Medical & Health Deptt. Govt. of Rajasthan.
2. P.S. to ACS/ PHS/ Secy., Medical Health & FW Deptt. Rajasthan, Jaipur.
3. PS to ACS/ PHS/ Secy., Medical Education Department, Rajasthan, Jaipur
4. P.S. to Mission Director NHM Jaipur.
5. PA to Managing Director, RMSCL
6. Director, (PH)/(Aids)/(FW)/(RCH)/(IEC)/(ESI).
7. Principal, Medical College, Ajmer, Bikaner, Jaipur, Jodhpur, Kota, Jhalawar & Udaipur.
8. Principal R.U.H.S. College of Dental Science Jaipur.
9. Principal, RUHS College of Medical Scinces, Jaipur.
10. Superintendent Japuriya Hospital Jaipur (Associated with RUHS College of Dental Science Jaipur)
11. Superintendent, SMS Hospital, Zenana Hospital, Mahila Chikitsalya, Medical College Hospital, T.B &

Validity unknown Signature valid

Digitally signed by D. Akash Alha  
Designation : Executive Director  
Date: 2024.04.26 08:45 IST

Reason: Approval



- Chest Hospital, Jaipur.
12. Superintendent Associated Group of Hospital-Ajmer, M.G. Hospital, Jodhpur, Ummaid Hospital- Jodhpur, PBM Hospital-Bikaner, MBS Hospital-Kota & A.G. Hospital-Udaipur.
  13. Director, Medical & Health Services (ESI), Mobile Surgical Unit, Raj. Jaipur.
  14. Addl. Director, Medical & Health Services (PW)/ (RH)/(Hospital Admn.)
  15. Joint Director, Medical & Health Services, (Zone) Jaipur, Ajmer, Udaipur, Jodhpur, Bikaner, Kota & Bharatpur.
  16. All CM&HO's., All P.M.O.'s. and All Dy. CM&HO's, Rajasthan.
  17. Joint Director (IT), for uploading in e-upkaran software and RMSCL website both.
  18. All BME, RMSC
  19. M/s RS Power System Pvt. Ltd., H1-85 RIICO Industrial Area, Mansarover, Jaipur, E-Mail:-  
rspower@rspowerindia.com
  20. Guard file.

Executive Director (EPM)

RMSC, Jaipur

RajKaj Ref  
5663618

Validity unknown Signature valid

Digitally signed by D. Akash Alha  
Designation : Executive Director  
Date: 2024.04.25 10:08:45 IST  
Reason: Approved

