



Rajasthan Medical Services Corporation Limited, Jaipur
Gandhi Block, Swasthya Bhawan, Tilak Marg, C-Scheme, Rajasthan, Jaipur

Phone No.-2223887, Fax no.-0141-2228065

E-Mail : edepmrmsc-rj@nic.in

CIN:U24232RJ2011SGC035067

Website: www.rmsc.health.rajasthan.gov.in

F-8(203) RMSC/EPM/M-7/NIB-524/2020-21/ 146

Date:- 22/10/2020

CLARIFICATION/CORRIGENDUM/ADDENDUM

Subject: -Clarification/Corrigendum/Addendum of NIB No. F-8(203) RMSC/EPM/M-7/NIB-524/2020-21/77 Dated 08.10.2020 for item Walk in Coolers (24, 32 & 40 cubic meter).

In Reference to subject cited above and NIB-524, the various representations received from the firms and issues raised by the bidders are examined by the competent authorities and technical committee. The following Clarification/Corrigendum/Addendum in the previous letter no. 141, dated 21.10.2020 is issued for inclusion in bid document as below:-

Following points in Technical Specification shall be read and replaced as under:-

4. In REFRIGERATION SYSTEM:-

- a. Dual refrigeration (100% standby) split type air cooled vapour compression refrigeration system with SS304/aluminium powder coated evaporator body (to avoid rust) and with EBM external rotor axial fans (minimum 3 fans of 300mm diameter) ceiling mounted-slim type (with less than 400mm height allowing more space for storing medicine), drain tray & drain pipe connection etc.
- f. **Condenser units consist of liquid receiver**, compressor oil separator, filters dryers, stop valves, high & low pressure switches, compressor motor overloads, compressor oil site glass, solenoid valves condenser fan & motor and other essential components.
- g. **Highly reliable scroll/reciprocating** compressor should be of reputed brand (Copeland, Danfoss, Kirloskar etc.) & capacity **should be minimum 20,000 BTU** to get the desired result. Compressor should be capable to with stand voltage fluctuation of $\pm 10\%$ of rated value. The compressor should auto cut after attaining the set temperature.

6. In SHELVING:-

- d. Shelf should be made from non corrosive **SS 304 stainless steel or higher and 6 feet height racks with 4 shelving**. Test report from NABL accredited lab/ steel manufacturer regarding quality of stainless steel grade should be enclosed from.

7. In DIESEL GENERATOR (DG) SET:-

- a. Minimum 10kVA DG set with AMF panel (3 Phase) for alternate supply.

52
22/10/2020

8. In SERVO STABLISERS:-

- a. Minimum 10kVA (three phase) for alternate.

CORRIGENDUM

1. In SECTION VI: QUALIFICATION AND EVALUATION CRITERIA (QEC), Mandatory Documents and/ or Standard required to meet Technical Criteria (Part-B), clause no. 2 shall be read and replace as under:-

b. Certificates/Brochures: Deleted


2. In SECTION VII : SPECIAL CONDITIONS OF RATE CONTRACT (SCC), point added
16. **The successful bidder shall have to establish local service centre in Rajasthan.**
17. **50% payment shall be made against the delivery of material at consignee and rest of the 50% payment shall be after successful installation, demonstration and commissioning.**

3. Revised Bid Schedule:

Please note that all clarification/amendment/corrigendum in technical specifications/bid conditions is the integral part of the bid document. This corrigendum/ addendum should be signed and annexed with bid document.

Previous Last Date & time of receipt of Bid Form	New Last Date & time of receipt of Bid Form	Previous Date & time of opening of technical bid	New Date & time of opening of technical bid
27.10.2020 06:00 PM	03.11.2020 06:00 PM	28.10.2020 11:00 AM	04.11.2020 11:00 AM

ALL OTHER TERMS & CONDITIONS OF THE BIDDING DOCUMENT SHALL REMAIN THE SAME.


Executive Director (EPM)
RMSCL, Jaipur