

Rajasthan Medical Services Corporation Limited, Jaipur**Gandhi Block, Swasthya Bhawan, Tilak Marg, C-Scheme, Jaipur - 302005**

Ph. No. 0141-2223887, Fax : 0141-2228065

E-mail : edepmrmsc-rj@nic.in

CIN:U24232RJ2011SGC035067

Website:www.rmsc.nic.in

No. F-8()RMSC/EPM/M-2/2016-17/NIB-210/ 417

Dated: 31/1/17

OFFICE ORDER

List of bidders declared responsive/non responsive as per documentary evaluation & technical evaluation of NIB No. F-8()RMSC/EPM/M-2/2016-17/NIB-210/6203 dated 19.12.16, technical bid opening date 03.01.2017. The list of bidders declared responsive/ non responsive as per decision taken in the purchase committee dated 31.01.17 headed by M.D., RMSCL:-

S. No.	Name of Firm	Quoted items	Responsive /Non responsive	Remarks
1.	M/s Micro Power technology Pvt. Ltd., Noida	5 KVA Inverter	Non Responsive	M/s Micro Power technology Pvt. Ltd., Noida के द्वारा कमीपूर्ति के दस्तावेजों में संलग्न Type Test Certificate/Report में आईटम Inverter 5 KVA की Input Voltage 160 V Is 260 V है, जबकि तकनीकी स्पेसिफिकेशन में Input Voltage 120 V से 260 V है। जिसके आधार पर तकनीकी रूप से स्पेसिफिकेशन के अनुरूप नहीं होने के कारण फर्म की निविदा Non Responsive मानी गई।
2.	M/s RS Power Sytems, Jaipur	5 KVA Inverter	Responsive	---
3.	M/s Pixels Electro Controls, Kota	5 KVA Inverter	Non Responsive	M/s Pixels Electro Controls, Kota के द्वारा कमीपूर्ति के दस्तावेजों में Type Test Certificate from Central Govt./NABL/ILEC Accredited Lab प्रस्तुत नहीं किया गया। अतः फर्म की निविदा Non Responsive मानी गई।

Online financial bids of responsive bidders for above item will be opened on dated 02.02.2017 at 03:00 P.M.

**Executive Director (EPM)
RMSCL, Jaipur**