

Rajasthan Medical Services Corporation Limited, Jaipur

Gandhi Block, Swasthya Bhawan, Tilak Marg, C-Scheme, Jaipur - 302005

Ph. No. 0141-2223887, Fax : 0141-2228065

CIN:U24232RJ2011SGC035067

E-mail : edepmrmisc-rj@nic.in

Website:www.health.rajasthan.

F-8() RMSC/EPM/M-4/NIB-479/2020-21/ 5197

Dated: 28/10/2020

All Principal, Medical Colleges,
All the Superintendent of Medical College & Attached Hospitals.
Director (PH/HA/IEC/AIDS/RCH)

Sub:- The Rate Contract for the 50 KVA Servo Stabilizer (Servo Motor Operated line Voltage Correctors).

Please find enclosed herewith approved firm and rates etc. in respect of Item **The Rate Contract for the 50 KVA Servo Stabilizer (Servo Motor Operated line Voltage Correctors)** for the rate contract ending on **31.10.2022**. The Rate Contract and its terms & conditions are also available on Rajasthan Medical Services Corporation Ltd., Website www.rmssc.health.rajasthan.gov.in.

In reference to above Rate Contract F-8() RMSC/EPM/M-4/NIB-479/2020-21/.....
Dated: the supplier has executed the agreement with RMSC, as enclose here for your information & necessary action.


Executive Director (EPM)

Rajasthan Medical Services Corporation Ltd, Jaipur

F-8() RMSC/EPM/M-4/NIB-479/2020-21/

Dated:

Copy forwarded to the following for information & necessary action:

22. P.S. to Hon'ble Health Minister, Medical & Health Deptt. Govt. of Rajasthan.
23. P.S. to PHS, Medical Health & FW Deptt. Rajasthan, Jaipur.
24. PS to Pr. Secy/Secy, Medical Education Department, Rajasthan, Jaipur
25. P.S. to Mission Director NHM Jaipur.
26. PA to Managing Director, RMSCL
27. Director, (PH)/(Aids)/(FW)/(RCH)/(IEC)/(ESI).
28. Principal, Medical College, Ajmer, Bikaner, Jaipur, Jodhpur, Kota, Jhalawar & Udaipur.
29. Principal R.U.H.S. College of Dental Science Jaipur.
30. Principal, RUHS College of Medical Sciences, Jaipur.
31. Superintendent Japuriya Hospital Jaipur (Associated with RUHS College of Medical Sciences, Jaipur).
32. Superintendent, SMS Hospital, Zenana Hospital, MahilaChikitsalya, Mental Hospital, J.K. Lon Hospital, T.B & Chest Hospital, Jaipur.
33. Superintendent Associated Group of Hospital-Ajmer, M.G. Hospital, Jodhpur, Ummaid Hospital- Jodhpur, PBM Hospital-Bikaner, MBS Hospital-Kota & A.G. Hospital-Udaipur.
34. Director, Medical & Health Services (ESI), Mobile Surgical Unit, Raj. Jaipur.
35. Addl. Director, Medical & Health Services (PW)/(RH)/(Hospital Admn.)
36. Joint Director, Medical & Health Services, (Zone) Jaipur, Ajmer, Udaipur, Jodhpur, Bikaner, Kota & Bharatpur.
37. All P.M.O.'s.
38. All CM&HO's.
39. All Dy. CM&HO's.
40. AGM (IT), RMSC, Jaipur.
41. M/s RS Power Systems Pvt. Ltd., H1-85, RIICO Industrial Area, Mansarovar, Jaipur-302020, Email : rspower@rspowerindia.com
42. Guard file.


Executive Director (EPM)

Rajasthan Medical Services Corporation Ltd, Jaipur



Rajasthan Medical Services Corporation Limited, Jaipur

Gandhi Block, Swasthya Bhawan, Tilak Marg, C-Scheme, Jaipur - 302005

Ph. No. 0141-2223887, Fax : 0141-2228065
CIN:U24232RJ2011ISGC035067

E-mail : edep@rmsc-ri@nic.in
Website:www.rmssc.health.rajasthan.gov.in

F-80 RMSC/EPMM-4/NIB-479/2020-21/5798

Dated: 28/10/2020

Order for Rate Contract

Item status: Manufacturer
Indicative Quantity: 30

| S. No. | Item | Detail |
|--------|---|--|
| 1. | Name of Equipment / Item | 50 KVA Servo Stabilizer (Servo Motor Operated line Voltage Correctors) |
| 2. | Name & Address of Firm | M/s RS Power Systems Pvt. Ltd, H1-85, RIICO Industrial Area, Mansarovar, Jaipur-302020 Email : rspower@rspowerindia.com, Contact Person: Rajeev Sharma, Mobile No. 9414639951 |
| 3. | Make | RS Power Power + |
| 4. | Model | - |
| 5. | Packing Unit | Each |
| 6. | R/C No. & Validity | (R.C. No 625 Valid upto 31.10.2022) |
| 7. | Net Rate Per packing Unit (Rs.) | 325000 (Rs. Three Lacs Twenty Five Thousand Only) HSN Code 9032 |
| 8. | RMSC Surcharge @5% | Rs. 1625.00 |
| 9. | Rates for Supply to RMSC from Suppliers | |
| | (i) Basic Rate (In Rs.) | 325000 |
| | (ii) IGST @ % (In Rs.) | 0.00 |
| | (iii) CGST @ 9 % (In Rs.) | 29250 |
| | (iv) SGST @ 9% (In Rs.) | 29250 |
| | (v) Approved Rate for Suppliers From RMSC {(i)+(ii)+(iii)+(iv)} (In Rs.) | 383500 |

[Handwritten Signature]
28/10/2020



10.

Rate for Supply To Consignee From RMSC

| | | |
|-------|--|-----------|
| (i) | Basic Rate (In Rs.) | 325000 |
| (ii) | RMSC Surcharge @ 5% on (In Rs.) | 1625.00 |
| (iii) | CGST @ 9% {On (i)+(ii)} (In Rs.) | 29396.25 |
| (iv) | SGST @ 9% {On (i)+(ii)} (In Rs.) | 29396.25 |
| (v) | Approved Rate for Consignee From RMSC {(i)+(ii)+(iii)+(iv)} (In Rs.) | 385417.50 |

11.

Technical Specifications of 50KVA Servo Stabilizer (Servo Motor Operated Line Voltage Correctors)

1. Capacity should be 3 phase 50KVA.
2. Should have oil cooled cooling technology.
3. Type: - Indoor, floor mounting (Balanced/Unbalanced)
4. a) Input voltage range: - 120 to 280V AC
b) Output voltage: - 415V±1%
c) Output voltage adjustment: - ± 5%
d) Frequency range of operation: - 47 to 53Hz
e) Voltage Correction speed: - 35V/sec
f) Output Voltage accuracy :- ±1%
5. Should have solid-state electronic plug in PCB circuits for control.
6. Efficiency should be above 98% at full load above 95% at half load.
7. Should have adjustment facility for output voltage level and correction sensitivity.
8. Load losses should be: -
a) No load loss at maximum rate input voltage: - Less than 3% of the rated capacity.
b) No load loss at minimum rate input voltage: - Less than 3% of the rated capacity.
c) Full load loss at minimum rate input voltage: - Less than 5% of the rated capacity.
d) Full load loss at maximum rate input voltage: - Less than 5% of the rated capacity.
9. Maximum load loss and input voltage at which it occurs at minimum input.
10. Should have continuous duty cycle.
11. Should have short time overload capacity
a) Not less than 110% for 5 minute
b) Not less than 125% for 1 minute
12. Should have metering input voltmeter with selector switch, output voltmeter with selector switch, ammeter for R, Y, B input currents with selector switch.
13. Should have indications for input ON lamp (using LED type lamps): - Output- R, Y, B separate lamps (after MCCB), Output MCCB Trip.
14. Should have MCCB for OL & SC protection, input phase reversal, input single phasing protection.
15. Should have suitable bypass arrangement for bypassing the input supply to output and isolating the servo stabilizer for maintenance/repair.
16. Operating temperature: - Up to 50°C±2 °C
17. Operating humidity: - Up to 95% RH.
18. Should be supplied with transformer grade oil confirming to IS:335/IEC296 for proper installation as per demand of quoted item.
19. Should be supplied with armoured aluminum cable (ISI mark) from main bus bar panel to SMOLVC and SMOLVC to main bus bar panel for proper installation as per demand of quoted item.

Handwritten signature



20. Should have in built LCD display (20x2 matrix) for date, time, input voltage, output voltage and current.
21. Should have automatic switch off against under load/over load, over voltage, single phasing & short circuit.
22. Should have programming features (through 2 – parallel way resettable password for HV cut off set, LV cut off set, time delay set, operating mode (auto/manual).
23. Should be supplied with body painted using 7 tank process systems, earthing bolts, lifting hooks.
24. Unit should be confirming to IS: 9815 (Pt. 1)/1994 (Reaffirmed 2004) with latest amendments.
25. Should be supplied type test certificate of servo motor operated line voltage correctors of rating: 3x50kVA or Type Test certificate of higher rating should be attached in technical bid issued from the Central Govt. Laboratory viz. ETDC (STQC)/CPRI/ERTL/National Test House.
26. Pre dispatch inspection at factory premises of the firm from Central Govt. Inspection Agency like RITES/ETDC (STQC)/NTH.
27. Should be supplied with required all item in other accessories needed for functioning of item.
28. The installation & commissioning, testing should be completed by firm.
29. Guarantee shall be three years from the date of successful installation at consignee place.
30. CMC: - CMC will be given @ 5% (of net rate exclusive GST) and yearly escalation of 5% on last year's CMC price. The CMC may be awarded for five years (on yearly basis) after warranty period of product.

Executive Director (EPM)

Rajasthan Medical Services Corporation Ltd., Jaipur

F-80 RMSC/EPPM/M-4/NIB-479/2020-21/ 5198 Dated: 28/10/2020

Copy forwarded to the following for information & necessary action:

1. P.S. to Hon'ble Health Minister, Medical & Health Deptt. Govt. of Rajasthan.
2. P.S. to PHS, Medical Health & FW Deptt. Rajasthan, Jaipur.
3. PS to Pr. Secy/Secy, Medical Education Department, Rajasthan, Jaipur
4. P.S. to Mission Director NHM Jaipur.
5. PA to Managing Director, RMSCL
6. Director, (PH)/(Aids)/(FW)/(RCH)/(EC)/(ESI).
7. Principal, Medical College, Ajmer, Bikaner, Jaipur, Jodhpur, Kota, Jhalawar & Udaipur.
8. Principal R.U.H.S. College of Dental Science Jaipur.
9. Principal, RUHS College of Medical Sciences, Jaipur.
10. Superintendent Japuriya Hospital Jaipur (Associated with RUHS College of Medical Sciences, Jaipur).
11. Superintendent, SMS Hospital, Zenana Hospital, MahilaChikitsalya, Mental Hospital, J.K. Lon Hospital, T.B & Chest Hospital, Jaipur.
12. Superintendent Associated Group of Hospital-Ajmer, M.G. Hospital, Jodhpur, Ummaid Hospital- Jodhpur, PBM Hospital-Bikaner, MBS Hospital-Kota & A.G. Hospital-Udaipur.
13. Director, Medical & Health Services (ESI), Mobile Surgical Unit, Raj. Jaipur.
14. Addl. Director, Medical & Health Services (PW) (RH)/(Hospital Admn.)
15. Joint Director, Medical & Health Services, (Zone) Jaipur, Ajmer, Udaipur, Jodhpur, Bikaner, Kota & Bharatpur.
16. All P.M.O.'s.



17. All CM&HO's.
18. All Dy. CM&HO's.
19. AGM (IT), RMSC, Jaipur.
20. M/s RS Power Systems Pvt. Ltd., HI-85, RIICO Industrial Area, Mansarovar, Jaipur-302020, Email : rspower@rspowerindia.com
21. Guard file.

Executive Director (EPM)

Rajasthan Medical Services Corporation Ltd, Jaipur